



- ① GATE VALVES PLACED WHERE THE WATERMAIN COVER IS MORE THAN 7' WILL REQUIRE AN OPERATING NUT EXTENSION ROD TO MAINTAIN 6' BETWEEN THE OPERATING NUT AND THE FINISHED SURFACE. EXTENSION ROD TO BE MADE OF STEEL AND CENTERED IN VALVE BOX. (INCIDENTAL)

GATE VALVE ADAPTER

NOT TO SCALE
PLATE 6013

GATE VALVE ADAPTER

STANDARD DETAIL
PLATE NO:
6013

APPROVED: ADOPTED BY CITY COUNCIL ON JANUARY 12, 2004

REVISED: REVISION ADOPTED BY CITY COUNCIL ON DECEMBER 12, 2005

REMARKS:

SAINT PETER UTILITY STANDARD DETAIL

